

## **STRONG ROOM SPECIFICATIONS FOR BRANCH**

1. WALLS : R.C.C. (1:1 ½:3) 300 MM THICK  
REINFORCEMENT: 12 mm diameter to steel at 150 mm c/c both ways and both faces of wall (A formation of reinforcement mat of 150 mm x 150 mm on either face of the wall to be obtained)

The reinforcement shall be staggered in such a manner that any view taken at right angles to the mat formation would show reinforcement at every 75 mm centre to centre.

The above reinforcement is only the minimum and depending upon the structural requirements, the Structural Consultants for the work would design and detailed out actual reinforcement required but this shall not be less than what is specified above.

2. FLOOR : RCC (1:1 ½:3) 300 MM THICK  
reinforcement same as above.

3. CEILING : RCC (1:1 ½:3) 300 MM THICK  
reinforcement same as above.

Where it is not feasible to provide RCC slab as specified, the ceiling may be fortified with M. S. Grills consisting of 20 mm rods spaced 75 mm centre to centre in angle iron frame work.

Door/Ventilator: Defenders Quality or Improved Bankers quality of Godrej or Steelage make along with the ventilator.

Strong Room door and ventilator shall be fixed as per manufacturer's specifications.

